



1X4  
FORMED CHANNEL

REF. TO: AMERICAN  
DATE: 12/12/2012

DWG BY: DCE

TITLE: **500CDW**

SCALE: 1:24

DESCRIPTION: ABOVE GROUND, DOUBLE WALL  
10 GA. INNER/10 GA. OUTER  
STEEL PIT LUBE STORAGE TANK

FINISH: SURFACE PREP: SPCC SP-3; ONE  
SPRAY COAT OF PRIMER; OPT FINISH

CAPACITY: 499 GALLONS

APPROX. WEIGHT:



Underwriters  
Laboratories Inc.  
LISTED 142

LEGEND: ID - (QTY. OF OPENINGS) PART

A - (5) 2' FNPT FLANGE  
B - (1) 4' INNER E.VENT FLANGE  
C - (1) 6' OUTER E.VENT FLANGE

D - (2) FORGED LIFTING LUG  
E - RMP

**AMERICAN**  
LUBRICATION EQUIPMENT CORPORATION®

SIGNED APPROVAL: